

**Test Report/Prufbericht
 for intermixability / interchangeability test
 of Compression Tube Fittings
 über Austausch von Teilen der Rohrverbindungssystem
 der Druckrohrverschraubungen**

Report number/Bericht Nr. : 1803117682-001 dated 18-10-2016
Client/Auftraggeber : Vipal Enterprises Pvt Ltd
Inspection/Gegenstand der Prüfung : Intermixability / Interchangeability test of Compression Tube fittings
Inspection requirement/Prüfanforderungen: To certify that HAVI Brand of Double Compression Fittings are 100% part to part interchangeable and intermixable with Swagelok Tube Fittings
Marking/Kennzeichnung : HAVI

1. Inspection commission/Prüfaufgabe

Verifying tightness-equivalency of tube joint systems manufactured by HAVI and Swagelok.
 Reference standard for testing ASTM F 1387

2. Remark/Vorbemerkung


The parts of testing specimens bear same appearance but made from different manufacturers.

3. Details of Specimen/Prüflingbeschreibung

	HAVI	Swagelok	Tube
¼ inch ODT	Tube Cap/Blindkappe Front Ferrule/Vordere Klemmring Back Ferrule/Hinter Klemmring Nut/Mutter Union body/Verbindungskoper Material grades/Werkstoff: 316	Male Connector/ männlich Steckverbinder Front Ferrule/Vordere Klemmring Back Ferrule/Hinter Klemmring Nut/Mutter Material grades/Werkstoff: 316	1/4" OD x 1.2 mm Material grades/Werkstoff: TP316
3/8 inch ODT	Tube Cap/Blindkappe Front Ferrule/Vordere Klemmring Back Ferrule/Hinter Klemmring Nut/Mutter Union body/Verbindungskoper Material grades/Werkstoff: 316	Male Connector/ männlich Steckverbinder Front Ferrule/Vordere Klemmring Back Ferrule/Hinter Klemmring Nut/Mutter Material grades/Werkstoff: 316	3/8" OD x 0.88 mm Material grades/Werkstoff: TP316
½ inch ODT	Tube Cap/Blindkappe Front Ferrule/Vordere Klemmring Back Ferrule/Hinter Klemmring Nut/Mutter Union body/Verbindungskoper Material grades/Werkstoff: 316	Male Connector/ männlich Steckverbinder Front Ferrule/Vordere Klemmring Back Ferrule/Hinter Klemmring Nut/Mutter Material grades/Werkstoff: 316	1/2" OD x 0.88 mm Material grades/Werkstoff: TP316

INTERMIXABILITY / COMBINATION CHART /Kombinationstabelle

Size	1/4"ODT x 1.2mmThk	3/8"ODT x 0.88mmThk	1/2"ODT x 1.20mmThk
Tube Cap	Havi	Havi	Havi
Front Ferrule	Swagelok	Swagelok	Swagelok
Back Ferrule	Swagelok	Swagelok	Swagelok
Nut	Swagelok	Swagelok	Swagelok
Nut	Swagelok	Swagelok	Swagelok
Back Ferrule	Havi	Havi	Havi
Front Ferrule	Havi	Havi	Havi
Union	Havi	Havi	Havi
Front Ferrule	Swagelok	Swagelok	Swagelok
Back Ferrule	Swagelok	Swagelok	Swagelok
Nut	Havi	Havi	Havi
Nut	Havi	Havi	Havi
Front Ferrule	Havi	Havi	Havi
Back Ferrule	Havi	Havi	Havi
Male Connector	Swagelok	Swagelok	Swagelok



4.0 Inspection/Prüfungen

4.1 Tightness test/Dichtigkeitsprüfung:

The original package of parts for assembly of specimen was opened and witnessed. It has been confirmed that the pressure class of the parts with same size is provided by two manufacturers is identical.

The parts were assembled to specimen, and assembly is made as shown above.

The specimen is mounted on test bench to check the tightness. The pressure tightness test checked and no leakage observed.

5. Inspection result/Prüfergebnis

Size of specimen/Prüflingsgröße	1/4" ODT	3/8" ODT	1/2" ODT
Tube Wall Thickness	0.048"	0.035"	0.049"
Tube Hardness (HRB)	77/79	76/80	76/80
Material grades/Werkstoff	ASTM A 269 TP316	ASTM A 269 TP316	ASTM A 269 TP316
Test fluid/Prüfflüssigkeit	water	water	water
Test pressure/Prüfdruck (psig)	12000	5000	5500
Holding time/Haltezeit	5 minutes	5 minutes	5 minutes
Result of tightness Ergebnis der Dichtigkeitsprüfung	no leakage or pressure drop observed	no leakage or pressure drop observed	no leakage or pressure drop observed

Remark/ Bemerkung :

The testing results showed that no impact on perfect tightness could be found by exchanging parts of two manufacturers

The hydraulic test combination showed no visual determining leakage or other damage by applying pressure with water.

Under the static pressure or speedy application of pressure with water, no defect impacting tightness function was found where single part of tube joint compression fittings system have been intently, not intently as well, exchanged.

It comes to conclusion that the device safety will not be impacted by arising un-tightness through exchanging above mentioned single part, whereby no statement about the longer period of time, frequent load cycle is not given, and the production fluctuation is not determined.




18-01-2016

Sachin Patil
 TÜV Rheinland (India) Private Limited
 D.S Business Galleria; Office no – 1209; 12th Floor,
 L.B.S Marg; Kanjurmarg (W); Mumbai-400079
 Phone- +912261083700(Board); 912261083713 (Direct);
 Internet : <http://www.ind.tuv.com>

CIN :U72501KA1996PTC020653

Disclaimer:

This report reflects our findings during inspection in time and place according to the agreed scope of our performance or deliverables and does not release buyer and/or seller from their contractual responsibilities. This report does not construe any guarantee or warranty that the purchase contract between buyer and seller is fulfilled correctly and all performances have been delivered without any defect. Furthermore the report and its results does not affect any potential buyer's right to claim for compensation or remedy towards the seller/supplier of apparent or hidden defects not detected during our inspection or occurred afterwards.